
Winona Concrete & Pipe Products Ltd.

489 Main Street West, Grimsby, Ontario L3M 1T4

Ph. 905-945-8515 Email: info@winonaconcrete.com Fax. 905-945-1149 Southern Ontario Toll Free 800-361-8515

Drawings are dimensional (not necessarily to scale) with unit of measure in Inches unless otherwise noted.



RECOMMENDED EXCAVATION: Length 15'- 6" Width 10' Depth 6' - 10"

- **Bottom** of excavation must be level at perimeter & **slightly dished** (about 3") to centre. Small granular aggregate should be used for establishing level.
- **Backfilling** may be done once poly pipe is connected to tank & should be done evenly around entire tank. **DO NOT bump tank or drive within excavation area.** Tank may be filled once backfilling is complete.
- **Cistern** is swept clean prior to delivery. However, tank may become dirty during shipping and / or installation. Customer is responsible for final cleaning and sanitation prior to use.

Concrete Water Cistern

Date: Febl. 1, 2009

Model: CI-2600 (11,900 Litres)

Capacity: 2,600 Imp. Gallons

Product information

1) Access riser extends 18" above cistern surface to facilitate minimum 12" soil cover. Standard "Safe-Water" Stainless Steel Lockable, Drip-Proof, Hinged Riser Lid installed.

2) 1-1/4" PVC Coupling (2) pre-installed to facilitate pump & or water level alarm wiring into cistern. Plug(s) supplied should be glued into coupling if conduit not required.

3) 4" PVC (IPS) gasketed fittings (2) cast-in place & sealed with Sch 40 PVC caps. Caps removable for piping connections if desired.

4) Standard configuration includes one brass thru-tank fitting (1.25"FIPT) cast into tank wall. Sch 40 PVC piping & brass foot valve installed inside tank and brass nipple/elbow with 1-1/4" insert adapter installed outside tank (w/SS clamps provided).

Fittings sized for 1" 100 psi CSA Poly Pipe (pipe available upon request).

- 5) Available options include:
 - a) Traditional Style Concrete Riser Lid available if "Safe-Water" Stainless Riser Lid configuration NOT wanted.
 - b) Submersible pump system for inside cistern installation
 - c) Jet Pump system for in-house set-up
 - d) Water Level Indictor & Low-water alarm
 - e) Ultra-Violet Sterilizers, Reverse Osmosis Purifiers and Water Filtration systems
- 6a) Cement used is Normal Portland type 10 or 30 unless noted otherwise.
- b) Minimum 28-day Concrete Strength: 32 MPA
- c) Design Max Burial Depth (cover) 39"
- d) Not intended for use in areas of vehicular traffic loading.

